

# **Fire Incident Reporting and Systems Failure**

## **Fire Incident Reporting**

All fires shall be reported to the Agency for Health Care Administration, Field Operations, 2727 Mahan Drive, Building 1, Suite 145, Tallahassee, Florida 32308, (850) 412-4489, **by the next working day after the occurrence.**

A "Fire Incident Report, AHCA #3500-0031, May 1998" must be completed and returned to the Office of Plans and Construction within 15 calendar days of the fire event. All reports shall be complete and thorough. This report can be accessed from the Agency's web site at

[www.ahca.myflorida.com/mchq/plans/](http://www.ahca.myflorida.com/mchq/plans/). Scroll to "Forms and Reports" and print the "Fire Incident Report" form. A "Fire Incident Report" form can also be obtained by calling Field Operations at (850) 412-4489.

### **Systems Failure**

In the event of a system failure of the fire alarm system, smoke detection system, power systems, or sprinkler system, the following actions shall be taken immediately by the facility:

1. Notify the local fire department and document instructions.
2. Notify the Agency for Health Care Administration through Field Operations.
3. Assess the extent of the condition and effect corrective action, with a documented period. If the corrective action will take more than four (4) hours, the following items shall be completed:
  - Implement a contingency plan to the facility fire plan containing: a description of the problem, a specific description of the system failure, and the projected correction period. All staff on shifts involved shall have documented in-service training for the emergency contingency.
  - Begin a documented fire watch, until the system is restored. Persons used for fire watch must be trained in what to look for, what to do, and be able to expeditiously contact the fire department. To maintain a fire watch, the facility shall utilize only certified public fire safety personnel, a guard service, or facility staff. If facility staff personnel are utilized for this function, they shall meet the following:
    - Be off duty from their regular facility position and be in compliance with current state staffing ratios and personnel policies;
    - Be trained and competent in the duties and responsibilities of a fire watch;
    - Have a provision for priority electronic communication
4. If the projected correction period changes or when the system is restored to normal operation, the facility shall notify the Agency for Health Care Administration and local fire authorities.