

ALERT: Boil Water Notice & Tier 1 Public Notice City of Sunrise - Population of 90,000 Plus

- A Tier 1 Public Notice with a Precautionary Boil Water Notice shall be issued to all customers served by the public water system including all consecutive systems and interconnects.

The Tier 1 Public Notice and Precautionary Boil Water Notice were triggered by the events mentioned below:

Wednesday July 13th, 2011	One distribution sample result was positive for Total Coliform. Well # 10 sample result was positive for Total Coliform.
Thursday July 14th, 2011	Well # 10 sample result was positive for Total Coliform and E. Coli.
Friday July 15th, 2011	Follow up samples were collected from the distribution site as well as upstream and downstream sites. Samples were collected from all wells. Well # 10 has been disconnected from the water treatment plant.

- Five samples must be taken from Well #10 within 24 hours of being notified of the fecal indicator positive result. Ensure that Well # 10 remains disconnected during sampling and until all corrective measures are completed and all bacteriological monitoring results are satisfactory. Please submit to this office all documentation of corrective measures and water test results prior to placing Well # 10 back into service.
- Bacteriological samples representing the geographical area of the distribution system served by public water system shall be taken until satisfactory results are obtained for two consecutive days.
- Once bacteriological analyses are satisfactory for two consecutive days on all samples, a rescission notice for the boil water notice may be issued.
- If any of the five samples from Well # 10 is positive for E. Coli, then corrective action must be taken in accordance with the Ground Water Rule and another Tier 1 Public Notice must be issued. Contact our office for further instructions.
- If any of the other wells tests positive for E. Coli, then another Tier 1 Public Notice must be issued and a five sample survey must be completed for that particular well. Contact our office for further instructions.
- Forward a copy of the proposed boil water notice and tier 1 public notice to this office for review before issuance. These notices must be issued today.
- Once the notices are issued forward official copies via email to this office today.

Rafael Reyes
Environmental Supervisor II
Broward County Health Department
2421A S.W. 6th Avenue Ft. Lauderdale, Fl. 33315
Phone: (954) 467-4700 x 4220 Fax: (954) 467-4898
E-Mail Address: rafael_reyes@doh.state.fl.us
Website: www.browardchd.org